

Jockimo™

Advanced Architectural Products

Product Guide Specification

January 20, 2008

Specifier Notes: This product guide specification is written according to the Construction Specifications Institute (CSI) 3-Part Format. The section must be carefully reviewed and edited by the Architect to meet the requirements of the project and local building code. Coordinate this section with other specification sections and the drawings. Delete all “Specifier Notes” when editing this section.

SECTION 8800

General Glazing – Glass Floor

PART 1 GENERAL

1.1 SECTION INCLUDES

A. Glass Flooring, Landings, or Treads.

1.2 RELATED SECTIONS

Specifier Notes: Edit the following list of related sections as required for the project. List other sections with work directly related to this section.

A. Section 8800 – General Glazing.

1.3 REFERENCES

A. ASTM C1048, standard specification for heat treated glass-kind HS, kind FT coated and uncoated

B. ASTM C1172-91, standard application for laminated architectural flat glass

C. ASTM C1036, Type 1-transparent, quality Q3-glazing select quality.

D. UL-410 Anti-Slip Certifications.

1.4 SUBMITTALS

A. Comply with Section 01330 - Submittal Procedures.

B. Product Data: Submit manufacturer's product data, including installation instructions.

C. Engineering Report: Submit Reports

1.5 DELIVERIES, STORAGE, AND HANDLING

- A. Delivery: Deliver materials to site in manufacturer's original, unopened containers and packaging, with labels clearly identifying product name and manufacturer.
- B. Storage: Store materials in clean, dry area indoors in accordance with manufacturer's instructions.
- C. Handling: Protect materials and finish from damage during handling and installation.

PART 2 PRODUCTS

2.1 MANUFACTURER

Specifier Notes: Three things to make sure when listing a manufacturer, 1) UL 410 approved anti-slip surface. 2.) Credible History. 3.) Provides Engineering Report for each project.

- A. Jockimo Inc. – AAG – 949-251-1560, fax 949-251-0126
- B. No Substitutions

2.2 MATERIALS

Specifier Notes: This may vary for numerous reasons – aesthetics, loading requirements, structural integrity, etc. Typically Flooring and landings are 3 layers of tempered glass and treads are 2 layers of tempered glass.

- A. Structural Requirements.
 - 1. Load Rating
 - 2. Deflection Rating
 - 3. Snow Loads
 - 4. Support Structure – concrete, wood, steel, other _____
 - 5. Full, partial, or perimeter support – number of inches/mm supported _____
- B. Glass Material:
 - 1. Clear Float Glass (green hue).
 - 2. Low Iron Glass (examples Optiwhite, Starfire, Eurowhite).
 - 3. Color Glass
- C. Glass Make up
 - 1. Top Layer - _____ Tempered Jockimo Anti-Slip GlassGrit™ Glass
 - 2. .060” Lamination Layer – Pour Resin, PVB, or EVA
 - 3. Middle Layer - _____ Tempered Glass
 - 4. .060” Lamination Layer – Pour Resin, PVB, or PVA
 - 5. Bottom Layer – _____ Tempered Glass, patten, or Slump cast glass
 - a. No opaque materials shall be included on the top surface.
- C. Aesthetic Qualities (*Options)
 - 1. Transparent, Translucent, or Opaque
 - 2. Frosted 3rd, 4th, or 5th surface

3. Logos
4. Color features within the glass

PART 3 EXECUTION

3.1 EXAMINATION

A. Examine areas to receive floor cleanouts. Notify Architect of conditions that would adversely affect installation or subsequent use. Do not proceed with installation until unsatisfactory conditions are corrected.

3.2 INSTALLATION

- A. Adhere to AAG's Structural Support Guidelines.
- B. Use Silicone compatible with laminated glass.
- C. Ensure that glass sits on a level surface.

3.3 PROTECTION

- A. Protect glass from damage during construction.

END OF SECTION

Jockimo Inc.
20101 SW Birch, Suite 276
Newport Beach, CA 92660
949.251.1560
949.251.0126 fax